



# Memo

## Hamburg Central School District

To: Board of Education  
Hamburg Community Members

From: Barbara S. Sporyz, Asst. Superintendent of Administrative Services & Finance

Date: January 25, 2017

Re: Remediation Status Update

In summary, of the 79 faucets that required remediation, 70 have been replaced and have passed a retest. Of the 9 outstanding, 7 have been retested a second time and we are waiting for the results. The remaining 2 are being further remediated. Please see below for a detailed account by building.

### **Boston Valley:**

**26 faucets** are being replaced to include 2 stops and 2 risers per faucet (Everything from the wall to the fixture). Estimated work completion date, to include retesting is the week of December 5, unless further remediation is required.

Current Status: **4 faucets failed the retest. Retesting a second time.**

**13 drinking fountains** (AKA "Bubblers", not refrigerated units) All units will be removed during Winter Recess, to include units that did not test positive for elevated levels requiring remediation.

Current Status: **All Bubblers have been removed.**

**2 (Filtered) Water Bottle Filling Stations** will be installed (1 per wing) by mid-January. More time is needed due to the installation requiring significant new plumbing.

Current Status: **Installed**

### **Armor Elementary:**

**23 faucets** are being replaced to include 2 stops and 2 risers per faucet (Everything from the wall to the fixture). Estimated work completion date, to include retesting is the week of December 5, unless further remediation is required.

Current Status: **1 faucet failed the retest. Retesting a second time.**

**11 drinking fountains** (AKA “Bubblers”, not refrigerated units) All units will be removed during Winter Recess, to include units that did not test positive for elevated levels requiring remediation.

Current Status: **All Bubblers have been removed.**

**2 (Filtered) Water Bottle Filling Stations** will be installed (1 per wing) by mid-January. More time is needed due to the installation requiring significant new plumbing.

Current Status: **Installed**

**Union Pleasant Elementary:**

**13 faucets** are being replaced to include 2 stops and 2 risers per faucet (Everything for the wall to the fixture). Estimated work completion date, to include retesting is the week of December 19, unless further remediation is required.

Current Status: **1 faucet failed the retest. Retesting a second time.**

**1 drinking fountain** (refrigerated) will be removed and replaced during Winter Recess with a **(Filtered) Water Bottle Filling Station**.

Current Status: **Installed**

“Bubblers”, (not refrigerated units) will be removed during Winter Recess, to include units that did not test positive for elevated levels requiring remediation.

Current Status: **All Bubblers have been removed.**

**Charlotte Avenue Elementary:**

**2 faucets** are being replaced to include 2 stops and 2 risers per faucet (Everything for the wall to the fixture). Estimated work completion date, to include retesting is the week of December 19, unless further remediation is required.

Current Status: **1 faucet failed the retest. Further remediation necessary.**

**Middle School:**

**10 faucets** are being replaced to include 2 stops and 2 risers per faucet (Everything for the wall to the fixture). Estimated work completion date, to include retesting is the week of December 19, unless further remediation is required.

Current Status: **1 faucet failed the retest. Further remediation necessary.**

**1 drinking fountain** (refrigerated) will be removed and will not be replaced due to the proximity of a nearby refrigerated fountain.

Current Status: **Removed**

**High School:**

**5 faucets** are being replaced to include 2 stops and 2 risers per faucet (Everything for the wall to the fixture). Estimated work completion date, to include retesting is the week of December 19, unless further remediation is required.

Current Status: **Completed**

**1 drinking fountain** (refrigerated) will be removed and replaced during Winter Recess with a **(Filtered) Water Bottle Filling Station**.

Current Status: **Removed/Installed**